

CERTIFICATE

Ship: ESTELLE AF ÖSTERGÖTLAND Call Sign: SFE9888

Home Port: ARKÖ

AEROSOL EXTINGUISHING SYSTEM

We hereby certify that the FIRE-PRO AEROSOL EXTINGUISHING SYSTEM for ENGINE this day have been checked on board the ESTELLE AF ÖSTERGÖTLAND in Arkö.

The Plant have been left in Good and Working Condition.

3 pcs Containers FP 100 FP 500 FP 200.

Installation date of containers 2023 x 2 2019 x 1.

Electric release system.

Release panel: FPC 104 C.

Fire detection central: 1 pc Smokedetectors.

Type of certificate: Total System Control (see reverse side)

Next service 2026-12

Stockholm 2025-12-09

Presto AB

Hans Larsson
Hans Larsson



Presto AB
Gävlegatan 22
113 30 Stockholm

Växel
+46 10-452 00 00

E-mail
marineservice@presto.se

Hemsida
www.presto.se

Org.nr
556112-0584

Type of certificate

Total System Control, includes checking of (when applicable):

- Content of container.
- Release wires.
- Electronic release system.
- Warning alarms
- Fanstops
- Initiators
- Connections
- Release function test
- Control units
- Mechanical fitting
- Signs
- Rust damages etc.



Presto AB
Gävlegatan 22
113 30 Stockholm

Växel
+46 10-452 00 00

E-mail
marineservice@presto.se

Hemsida
www.presto.se

Org.nr
556112-0584

CERTIFICATE

Ship: ESTELLE AF ÖSTERGÖTLAND Call Sign: SFC9888

Home Port: ARKÖSUND

FIRE EXTINGUISHERS

We hereby certify that the following equipment this day have been checked on board the ESTELLE AF ÖSTERGÖTLAND in Fyrudden.

All units have been left in Good and Working Condition.

3 pcs	CGS	P6	Dry Powder	type	6 kg
1 PC	CGS	K5	Carbon Dioxide	type	5 kg

Next service 2026-12

Stockholm 2025-12-09

Presto AB

Hans Larsson

Hans Larsson



Presto AB
Gävlegatan 22
113 30 Stockholm

Växel
+46 10-452 00 00

E-mail
marineservice@presto.se

Hemsida
www.presto.se

Org.nr
556112-0584

